

What are the errors in NetLinx that are returned on the Data Event, ONERROR?

Here is a listing of some of the ONERROR values for IP_CLIENT_CLOSE and IP_CLIENT OPEN:

Result (via ONERROR event):

- 2: General Failure
- 4: Unknown host
- 6: Connection refused
- 7: Connection timed out
- 8: Unknown connection error
- 9: Already closed
- 10: Binding error
- 11: Listening error
- 14: Local port already used
- 15: UDP socket already listening
- 16: Too many open sockets

These are listed in the NetLinx Programming Language Manual on pages 122 through 124. You can also find other error messages that relate to specific functions listed in this section of the manual called "Keywords and Run-Time Library Functions."

About HARMAN Professional Solutions

HARMAN Professional Solutions is the world's largest professional audio, video, lighting, and control products and systems company. Our brands comprise AKG Acoustics®, AMX®, BSS Audio®, Crown International®, dbx Professional®, DigiTech®, JBL Professional®, Lexicon Pro®, Martin®, Soundcraft® and Studer®. These best-in-class products are designed, manufactured and delivered to a variety of customers in markets including tour, cinema and retail as well as corporate, government, education, large venue and hospitality. For scalable, high-impact communication and entertainment systems, HARMAN Professional Solutions is your single point of contact. www.harmanpro.com